



PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, KURUKSHETRA

Website :- <https://phedharyana.gov.in/>

Memo No:- 164

Date:- 13/03/2024

Subject : **Bacteriological Examination Report of Water Sample**

Sample Details		Date & Time
Sample ID:	KKR/04342/3/2024	
Sample Classification:	Private	Collected By
Sender:	RENU KAMAL28900	RENU KAMAL,9467042118
Location :-	PMSHRI GSSS BANI , LADWA	Collection Date
		11/03/2024 at 09:50
Latitude :-	77.111285	Received at lab
Longitude :-	29.963309	11/03/2024 at 14:43
		Tested at Lab
		13/03/2024

Test Result (As Per BIS 10500 :2012)


S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	28	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in KURUKSHETRA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found **"NOT CONFORMING "** to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found **"NOT POTABLE"**




NISHA SAINI,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY KURUKSHETRA
email:-chemist.kkra@phedharyana.gov.in

-----End of Report-----.